

Appendix 2

Overivew of Asbestos Products in Caerphilly Owned Schools

Category Rating:

- 1) Damaged licenced product in occupied area(s).
- 2) Licenced product in occupied area(s) prone to damage.
- 3) Licenced product in occupied area(s) not prone to damage
- 4) No Licenced product in occupied area(s).
- 5) ACM free

Abbreviations:

AIB Asbestos Insulation Board
 ACMs Asbestos Containing Mate

| Premise | Category Rating | Prohibitions | Restrictions | Permission | Current Position at each School |
|-------------------------|-----------------|--------------|--------------|------------|--|
| Bedwas Infants | 2 | x | x | | AIB wall panels in several Classrooms. |
| Bedwas Juniors | 2 | | x | | AIB wall panel behind heater in one classroom. |
| Blackwood Comprehensive | 2 | x | x | x | AIB ceilings and skylights to several areas. Lagging debris within Boiler House. |
| Cefn Fforest Primary | 2 | | x | | AIB ceiling tiles in Kitchen areas. Lagging debris within Boiler House. |
| Coed Y Brain Primary | 2 | | x | | AIB wall panel within WC and store area. |
| Fochriw Primary | 2 | x | x | | Lagging debris within two Boiler Houses. |
| Graig Y Rhacca Primary | 2 | x | x | x | AIB wall panels and AIB ceilings in several occupied areas. |
| Hendre Infants | 2 | | x | | AIB ceilings in toilet areas. Lagging debris to two Boiler Houses. |
| Heolddu Comprehensive | 2 | x | x | x | AIB boxing/cladding around metal columns throughout buildings |
| Lewis Girls School | 2 | x | x | x | AIB wall panels in several Classrooms. |
| Newbridge School | 2 | x | x | x | AIB wall panels above several doors, AIB ceiling tiles to several areas. |
| Oakdale Comprehensive | 2 | x | x | x | AIB wall panels and AIB ceiling tiles to several areas. |
| Pantside Primary | 2 | | | | One AIB wall panel to circulation area. |

| Premise | Category Rating | Prohibitions | Restrictions | Permission | Current Position at each School |
|-------------------------------|-----------------|--------------|--------------|------------|---|
| Plasfelin Primary | 2 | x | | x | AIB ceilings to Kitchen areas. AIB debris to Tank Room. |
| Pontllanfraith Comprehensive | 2 | x | x | x | AIB wall panels and AIB ceiling tiles to several areas. |
| Risca Community Comprehensive | 2 | x | | x | AIB wall panels above several doors. |
| St Cenydd Comprehensive | 2 | x | x | x | AIB wall panels to occupied area and AIB ceiling tiles to two |
| St Martins Comprehensive | 2 | x | x | x | AIB boxing /cladding around metal columns throughout buildings. AIB ceiling tiles to several locations. |
| Tir Y Berth Primary | 2 | x | x | | Lagging debris within Boiler House. |
| Trinant Primary | 2 | x | x | | Lagging to pipework in Kitchen. |
| Tyn Y Wern Primary | 2 | x | x | | Lagging to pipework in circulation area. |
| Ynysddu Primary | 2 | x | x | | Lagging debris within Boiler House. |
| Ysgol Gymraeg Cwm Derwen | 2 | x | x | | Lagging to pipework in dining room. AIB ceiling in Boiler House. |
| Ystrad Mynach Primary | 2 | | x | | Lagging debris within Boiler House. |
| Abercarn Primary | 3 | | | | AIB ceiling in one Classroom. |
| Abertyswg Primary | 3 | | x | | AIB heater plinth in Classroom. |
| Bedwas High School | 3 | x | x | x | AIB ceiling tiles to several occupied areas. |
| Blackwood Primary | 3 | | x | x | Encapsulated AIB ceiling panels to Boiler House. |
| Bryn Primary | 3 | | x | | AIB to underside of shelf in circulation area. |
| Crumlin High Level Primary | 3 | x | | | AIB ceiling tiles in Kitchen areas. |
| Cwmaber Infants | 3 | x | x | | AIB skylights in Nursery Classroom. |
| Cwmcarn Primary | 3 | | x | | AIB ceilings to Kitchen areas. |
| Gilfach Fargoed Primary | 3 | | x | | AIB ceiling panels in Boiler House. |
| Hendredenny Primary | 3 | x | x | x | AIB vent shafts to three Store Rooms. |
| Llancaeath Juniors | 3 | | | | AIB ceilings to Kitchen toilet. |
| Ty Isaf Infants | 3 | x | x | | Overboarded AIB wall panels to several areas. |
| Ty Sign Primary | 3 | x | x | | Overboarded AIB wall panels to several classrooms. |
| Aberbargoed Primary | 4 | | | | No licenced ACMs in occupied areas. |
| Cwm Glas Infants | 4 | | x | x | No licenced ACMs in occupied areas. |
| Cwmaber Juniors | 4 | | | | No licenced ACMs in occupied areas. |
| Cwmfelinfach Primary | 4 | | x | | No licenced ACMs in occupied areas. |
| Deri Primary | 4 | | x | | No licenced ACMs in occupied areas. Gasket debris to floor of Boiler House. |

| Premise | Category Rating | Prohibitions | Restrictions | Permission | Current Position at each School |
|--------------------------------|-----------------|--------------|--------------|------------|-------------------------------------|
| Derwendeg Primary | 4 | | x | | No licenced ACMs in occupied areas. |
| Fleur-De-Lys Primary | 4 | | x | | No licenced ACMs in occupied areas. |
| Glanynant, The Learning Centre | 4 | | | | No licenced ACMs in occupied areas. |
| Glyn Gaer Primary | 4 | x | x | x | No licenced ACMs in occupied areas. |
| Hendre Juniors | 4 | | | | No licenced ACMs in occupied areas. |
| Hengoed Primary | 4 | | x | x | No licenced ACMs in occupied areas. |
| Libanus Primary | 4 | | | | No licenced ACMs in occupied areas. |
| Llanfabon Infants | 4 | | | | No licenced ACMs in occupied areas. |
| Machen Primary | 4 | x | x | | No licenced ACMs in occupied areas. |
| Maesycwmmmer Primary | 4 | | x | | No licenced ACMs in occupied areas. |
| Markham Primary | 4 | | | | No licenced ACMs in occupied areas. |
| Nantyparc Primary | 4 | | | | No licenced ACMs in occupied areas. |
| Park Primary | 4 | | x | | No licenced ACMs in occupied areas. |
| Pengam Primary | 4 | | | | No licenced ACMs in occupied areas. |
| Penllwyn Primary | 4 | | | | No licenced ACMs in occupied areas. |
| Pentwynmawr Primary | 4 | | x | | No licenced ACMs in occupied areas. |
| Phillipstown Primary | 4 | | x | | No licenced ACMs in occupied areas. |
| Pontllanfraith Primary | 4 | | | | No licenced ACMs in occupied areas. |
| Pontlloftyn Primary | 4 | | x | | No licenced ACMs in occupied areas. |
| Rhiw Syr Dafydd Primary | 4 | | | | No licenced ACMs in occupied areas. |
| Rhydri Primary | 4 | | | | No licenced ACMs in occupied areas. |
| Rhymney Comprehensive | 4 | | x | | No licenced ACMs in occupied areas. |
| Risca Primary | 4 | | | | No licenced ACMs in occupied areas. |
| St Gwladys Primary | 4 | x | x | | No licenced ACMs in occupied areas. |
| The Twyn School | 4 | | x | | No licenced ACMs in occupied areas. |
| Trinity Fields | 4 | | | | No licenced ACMs in occupied areas. |
| Tynewydd Primary | 4 | | | | No licenced ACMs in occupied areas. |
| Upper Rhymney Primary | 4 | x | x | x | No licenced ACMs in occupied areas. |
| Waunfawr Primary | 4 | | x | | No licenced ACMs in occupied areas. |
| Ysgol Bro Sannan | 4 | | | | No licenced ACMs in occupied areas. |
| Ysgol Gymraeg Bro Allta | 4 | | x | | No licenced ACMs in occupied areas. |
| Ysgol Gymraeg Gilfach Fargoed | 4 | | | | No licenced ACMs in occupied areas. |

| Premise | Category Rating | Prohibitions | Restrictions | Permission | Current Position at each School |
|---------------------------------|-----------------|--------------|--------------|------------|-------------------------------------|
| Ysgol Gymraeg Trelyn | 4 | | x | | No licenced ACMs in occupied areas. |
| Ysgol Gynradd Cwm Gwyddon | 4 | | | | No licenced ACMs in occupied areas. |
| Ysgol Gynradd Gymraeg Caerffili | 4 | | | | No licenced ACMs in occupied areas. |
| Ysgol Gynradd Gymraeg Y Castell | 4 | x | x | | No licenced ACMs in occupied areas. |
| Ysgol Y Lawnt | 4 | | | | No licenced ACMs in occupied areas. |
| Bryn Awel Primary | 5 | | | | Asbestos Free. |
| Cwm Ifor Primary | 5 | | | | Asbestos Free. |
| Cwrt Rawlin Primary | 5 | | | | Asbestos Free. |
| Greenhill Primary | 5 | | | | Asbestos Free. |
| St James Primary | 5 | | | | Asbestos Free. |
| White Rose Primary | 5 | | | | Asbestos Free. |
| Ysgol Ifor Bach | 5 | | | | Asbestos Free. |
| Ysgol Penalltau | 5 | | | | Asbestos Free. |

1
Materials

| Recommendations to be completed by December 2016 |
|---|
| Remove AIB wall panels. |
| Remove AIB wall panels. |
| Environmental clean of Boiler House, removal of AIB ceilings and skylights. |
| Localised clean of Boiler House and removal of AIB ceilings. |
| Remove AIB wall panels. |
| Environmental clean of two Boiler Houses. |
| Remove AIB wall panels & AIB ceilings. |
| Remove AIB ceilings and Environmental clean of two Boiler Houses. |
| Overboard AIB boxing/cladding. |
| Overboard/remove where possible AIB wall panels. |
| Remove AIB wall panels and ceilings. |
| Overboard AIB wall panels. |
| Remove AIB wall panel. |

**Recommendations to be completed by
December 2016**

Remove of AIB ceiling and localised clean of Tank Room.

Overboard AIB wall panels.

Remove AIB wall panels.

Remove AIB wall panels and ceilings.

Overboard AIB boxing/cladding and removal of AIB ceilings.

Environmental clean of Boiler House.

Remove lagging.

Remove lagging.

Environmental clean of Boiler House.

Remove lagging and remove AIB ceiling.

Environmental clean of Boiler House.

Remove AIB ceilings.

Remove AIB heater plinth.

Remove AIB ceilings.

Remove AIB shelf.

Remove AIB ceilings.

Remove AIB skylights.

Remove AIB ceilings.

Remove/Encapsulate AIB ceiling panels.

Remove AIB vent shafts.

Remove AIB ceilings.

Localised clean of Boiler House.

