

Appendix 2

Overview of Asbestos Products in Caerphilly Owned Schools

Category Rating:

- 1) Damaged licenced product in occupied area(s).
- 2) Licenced product in occupied area(s) prone to damage.
- 3) Licenced product in occupied area(s) not prone to damage
- 4) No Licenced product in occupied area(s).
- 5) ACM free

Abbreviations:

- AIB Asbestos Insulation Board
ACMs Asbestos Containing Materials

Premise	Category Rating	Prohibitions	Restrictions	Permission	Current Position at each School	Recommendations to be completed by December 2016
Bedwas Infants	2	x	x		AIB wall panels in several Classrooms.	Remove AIB wall panels.
Bedwas Juniors	2		x		AIB wall panel behind heater in one classroom.	Remove AIB wall panels.
Blackwood Comprehensive	2	x	x	x	AIB ceilings and skylights to several areas. Lagging debris within Boiler House.	Environmental clean of Boiler House, removal of AIB ceilings and skylights.
Cefn Fforest Primary	2		x		AIB ceiling tiles in Kitchen areas. Lagging debris within Boiler House.	Localised clean of Boiler House and removal of AIB ceilings.
Coed Y Brain Primary	2		x		AIB wall panel within WC and store area.	Remove AIB wall panels.
Fochriw Primary	2	x	x		Lagging debris within two Boiler Houses.	Environmental clean of two Boiler Houses.
Graig Y Rhacca Primary	2	x	x	x	AIB wall panels and AIB ceilings in several occupied areas.	Remove AIB wall panels & AIB ceilings.
Hendre Infants	2		x		AIB ceilings in toilet areas. Lagging debris to two Boiler Houses.	Remove AIB ceilings and Environmental clean of two Boiler Houses.
Heolddu Comprehensive	2	x	x	x	AIB boxing/cladding around metal columns throughout buildings	Overboard AIB boxing/cladding.
Lewis Girls School	2	x	x	x	AIB wall panels in several Classrooms.	Overboard/remove where possible AIB wall panels.
Newbridge School	2	x	x	x	AIB wall panels above several doors, AIB ceiling tiles to several areas.	Remove AIB wall panels and ceilings.
Oakdale Comprehensive	2	x	x	x	AIB wall panels and AIB ceiling tiles to several areas.	Overboard AIB wall panels.
Pantside Primary	2				One AIB wall panel to circulation area.	Remove AIB wall panel.
Plasfelin Primary	2	x		x	AIB ceilings to Kitchen areas. AIB debris to Tank Room.	Remove of AIB ceiling and localised clean of Tank Room.
Pontllanfraith Comprehensive	2	x	x	x	AIB wall panels and AIB ceiling tiles to several areas.	Overboard AIB wall panels.
Risca Community Comprehensive	2	x		x	AIB wall panels above several doors.	Remove AIB wall panels.
St Cenydd Comprehensive	2	x	x	x	AIB wall panels to occupied area and AIB ceiling tiles to two	Remove AIB wall panels and ceilings.
St Martins Comprehensive	2	x	x	x	AIB boxing /cladding around metal columns throughout buildings. AIB ceiling tiles to several locations.	Overboard AIB boxing/cladding and removal of AIB ceilings.
Tir Y Berth Primary	2	x	x		Lagging debris within Boiler House.	Environmental clean of Boiler House.
Trinant Primary	2	x	x		Lagging to pipework in Kitchen.	Remove lagging.
Tyn Y Wern Primary	2	x	x		Lagging to pipework in circulation area.	Remove lagging.
Ynysddu Primary	2	x	x		Lagging debris within Boiler House.	Environmental clean of Boiler House.
Ysgol Gymraeg Cwm Derwen	2	x	x		Lagging to pipework in dining room. AIB ceiling in Boiler House.	Remove lagging and remove AIB ceiling.
Ystrad Mynach Primary	2		x		Lagging debris within Boiler House.	Environmental clean of Boiler House.
Abercarn Primary	3				AIB ceiling in one Classroom.	Remove AIB ceilings.
Abertyswg Primary	3		x		AIB heater plinth in Classroom.	Remove AIB heater plinth.
Bedwas High School	3	x	x	x	AIB ceiling tiles to several occupied areas.	Remove AIB ceilings.
Blackwood Primary	3		x	x	Encapsulated AIB ceiling panels to Boiler House.	
Bryn Primary	3		x		AIB to underside of shelf in circulation area.	Remove AIB shelf.
Crumlin High Level Primary	3	x			AIB ceiling tiles in Kitchen areas.	Remove AIB ceilings.
Cwmaber Infants	3	x	x		AIB skylights in Nursery Classroom.	Remove AIB skylights.
Cwmcarn Primary	3		x		AIB ceilings to Kitchen areas.	Remove AIB ceilings.
Gilfach Fargoed Primary	3		x		AIB ceiling panels in Boiler House.	Remove/Encapsulate AIB ceiling panels.
Hendredenny Primary	3	x	x	x	AIB vent shafts to three Store Rooms.	Remove AIB vent shafts.
Llancaeath Juniors	3				AIB ceilings to Kitchen toilet.	Remove AIB ceilings.
Ty Isaf Infants	3	x	x		Overboarded AIB wall panels to several areas.	
Ty Sign Primary	3	x	x		Overboarded AIB wall panels to several classrooms.	
Aberbargoed Primary	4				No licenced ACMs in occupied areas.	
Cwm Glas Infants	4		x	x	No licenced ACMs in occupied areas.	
Cwmaber Juniors	4				No licenced ACMs in occupied areas.	
Cwmfelinfach Primary	4		x		No licenced ACMs in occupied areas.	
Deri Primary	4		x		No licenced ACMs in occupied areas. Gasket debris to floor of Boiler House.	Localised clean of Boiler House.
Derwendeg Primary	4		x		No licenced ACMs in occupied areas.	
Fleur-De-Lys Primary	4		x		No licenced ACMs in occupied areas.	
Glanynant, The Learning Centre	4				No licenced ACMs in occupied areas.	
Glyn Gaer Primary	4	x	x	x	No licenced ACMs in occupied areas.	
Hendre Juniors	4				No licenced ACMs in occupied areas.	
Hengoed Primary	4		x	x	No licenced ACMs in occupied areas.	
Libanus Primary	4				No licenced ACMs in occupied areas.	
Llanfabon Infants	4				No licenced ACMs in occupied areas.	
Machen Primary	4	x	x		No licenced ACMs in occupied areas.	
Maesycwmmmer Primary	4		x		No licenced ACMs in occupied areas.	
Markham Primary	4				No licenced ACMs in occupied areas.	
Nantyparc Primary	4				No licenced ACMs in occupied areas.	
Park Primary	4		x		No licenced ACMs in occupied areas.	
Pengam Primary	4				No licenced ACMs in occupied areas.	
Penllwyn Primary	4				No licenced ACMs in occupied areas.	

Premise	Category Rating	Prohibitions	Restrictions	Permission	Current Position at each School	Recommendations to be completed by December 2016
Pentwynmawr Primary	4		x		No licenced ACMs in occupied areas.	
Phillipstown Primary	4		x		No licenced ACMs in occupied areas.	
Pontllanfraith Primary	4				No licenced ACMs in occupied areas.	
Pontlloftyn Primary	4		x		No licenced ACMs in occupied areas.	
Rhiw Syr Dafydd Primary	4				No licenced ACMs in occupied areas.	
Rhydri Primary	4				No licenced ACMs in occupied areas.	
Rhymney Comprehensive	4		x		No licenced ACMs in occupied areas.	
Risca Primary	4				No licenced ACMs in occupied areas.	
St Gwladys Primary	4	x	x		No licenced ACMs in occupied areas.	
The Twyn School	4		x		No licenced ACMs in occupied areas.	
Trinity Fields	4				No licenced ACMs in occupied areas.	
Tynwydd Primary	4				No licenced ACMs in occupied areas.	
Upper Rhymney Primary	4	x	x	x	No licenced ACMs in occupied areas.	
Waunfawr Primary	4		x		No licenced ACMs in occupied areas.	
Ysgol Bro Sannan	4				No licenced ACMs in occupied areas.	
Ysgol Gymraeg Bro Allta	4		x		No licenced ACMs in occupied areas.	
Ysgol Gymraeg Gilfach Fargoed	4				No licenced ACMs in occupied areas.	
Ysgol Gymraeg Trelyn	4		x		No licenced ACMs in occupied areas.	
Ysgol Gynradd Cwm Gwyddon	4				No licenced ACMs in occupied areas.	
Ysgol Gynradd Gymraeg Caerffili	4				No licenced ACMs in occupied areas.	
Ysgol Gynradd Gymraeg Y Castell	4	x	x		No licenced ACMs in occupied areas.	
Ysgol Y Lawnt	4				No licenced ACMs in occupied areas.	
Bryn Awel Primary	5				Asbestos Free.	
Cwm Ifor Primary	5				Asbestos Free.	
Cwrt Rawlin Primary	5				Asbestos Free.	
Greenhill Primary	5				Asbestos Free.	
St James Primary	5				Asbestos Free.	
White Rose Primary	5				Asbestos Free.	
Ysgol Ifor Bach	5				Asbestos Free.	
Ysgol Penalltau	5				Asbestos Free.	