

**Appendix 7 - Existing Parking Bay Provisions in Pay & Display Car Parks**

Car Park Name	No. of Standard Parking Bays	Size of Standard Parking Bays (mm)		No. of Disabled Bays	Size of Disabled Parking Bays (mm)			% of Disabled Bays Provided	No. of Tariff Signs	X' ht of Tariff Board (mm)	X' ht of T&C Board (mm)	Comments/Actions
		Width	Length		Width	Length	Hatching					
Emporium, Bargoed	25	2400	4800	2	2450	4800	1500	7.4	1	30	16	1 no. additional disabled bay required
St Gwladys, Bargoed	24	2400	5000	3	2400	5000	None	11	1	20	16	
Ystrad Mynach	68	2400	4800	1	2450	4300	600-900	1.4	2	25	16	4 no. additional disabled bays required. 1 no. existing disabled bay to be increased in size
Bedwas Road, Caerphilly	20	2200	4700	3	2350	5000	1260	13	1	20	16	
Station Terrace, Caerphilly	24	2450	5000	2	2400	4700	None	7.7	1	20	16	2 no. existing disabled bays to be increased in length. 1 no. additional disabled bay required.
Crescent Road, Caerphilly S/S	70	2450	5000	4	2450	4600	1260	5.4	1	25	16	1 no. additional disabled parking required. 4 no. existing disabled bays to be increased in length
Crescent Road, Caerphilly L/S	112	2350	4900	3	2400	4700	1200	2.6	3	20	16	4 no. additional disabled bays required. 3 no. existing disabled bays to be increased in length.
Twyn, Caerphilly	61	2400	4800	7	2400	4650	1300	10.3	3	20	16	7 no. existing disabled bays to be increased in length
Cliff Road, Blackwood	90	2400	4800	6	2400	4600	1200	6.25	2	25	15	6 no. existing disabled bays to be increased in length
Wesley Road, Blackwood	30	2400	4800	1	2500	4900	2240	3.2	1	25	15	2 no. additional disabled bays required
Woodbine Road, Blackwood	35	2400	4600	2	2630	4900	1340	5.4	1	25	15	1 no. additional disabled bay required
Bus Station, Blackwood	50	2440	4600	3	2400	4650	1200	5.6	2	25	15	1 no. additional disabled bay required. 3 no. existing disabled parking bays to be increased in length.
Market Traders, Blackwood	23	2420	4700	1	2440	4700	1130	4.1	1	25	15	2 no. additional disabled bay required. 1 no. existing disabled parking bay to be increased in length.
Thorncombe Road 2, Blackwood	35	2430	4700	0				0	2	25	15	Shortage of disabled bays offset by increased number provided in Thorncombe 3
Thorncombe Road 3, Blackwood	69	2340	4600	17	2450	4750	1200	19.7	3	25	15	
High Street, Blackwood	193	2450	4540	8	2430	4600	1200	3.7	5	25	15	4 no. additional disabled bays required. 8 no. existing disabled parking bays to be increased in length.
Court House, Blackwood	41	2400	4600	0				0	1	20	15	3 no. additional disabled bays required
Red Lion, Blackwood	11	2540	4250	0				0	1	15	15	3 no. additional disabled bays required

Number of disabled bays recommended by LTN 5/95

Car Park Used For:

Up to 200 Bays

Over 200 Bays

Minimum Recommended Size of Parking Bays

Employees & visitors to business premises

Individual bays for each disabled employees plus 2 bays or 5% of total capacity whichever is greater

6 bays plus 2% of total capacity

Standard Parking Bay - 2400x4800mm

Shopping, recreation and leisure

3 bays or 6% of total capacity whichever is greater

4 bays plus 4% of total capacity

Disabled Parking Bay - 3600 x4800mm (including 1200mm wide hatching except when end bay)